



Attestation of Conformity

ISO/IEC, EN & TIA/EIA Screen Continuity Class E / Category 6 Two Connector Channel

Bticino S.p.A
via Massina 38
I-20154 Milano, Italy

Attestation of Conformity No. 109619

This type of Class E / Category 6 screen continuity two connector channel has been tested by 3P Third Party Testing and complies with Class E channel requirements of 2nd Edition ISO/IEC 11801 and CENELEC EN 50173-1:2007, and Category 6 channel requirements of ANSI/TIA/EIA-568-B.2-1. The channel is only specified for screen continuity and screening performance has therefore not been verified. The Attestation of Conformity is only valid for the actually tested channel samples in T568B configuration, and consisting of the following Bticino components:

<i>Cables:</i>	<i>Horizontal Cable, Flexible Cable from cords, Qualification Status:</i>	<i>P/N 32757 P/N 51752, P/N 51753, P/N 51754 and P/N 51755 Manufacturer verified</i>
<i>Conn. Hardware:</i>	<i>Modular Jacks, Qualification Status:</i>	<i>P/N SA53 and P/N SB53 having PCB Marking HS000 97AA C5E C6 Manufacturer Verified</i>
<i>Cords:</i>	<i>1,0 m, 2,0 m, 3,0 m and 5,0 m, Qualification Status:</i>	<i>P/N 51752, P/N 51753, P/N 51754 and P/N 51755 Manufacturer Verified</i>

Hoersholm, 14th July 2009

Ole Lambertsen

Ole Lambertsen
Test Responsible

Hoersholm, 14th July 2009

Paul Villien

Poul Villien
Coordinating Manager