



# Attestation of Conformity

## ISO/IEC, EN & TIA/EIA Screen Continuity Class E<sub>A</sub> / Category 6A Two Connector Permanent Link

**Legrand**  
**128 Avenue de Lattre de Tassigny**  
**F-87045 Limoges Cedex, France**

### *Attestation of Conformity No. 109601*

*This type of Class E<sub>A</sub> / Category 6A screen continuity two connector permanent link has been tested by 3P Third Party Testing and complies with the 10 Gigabit Ethernet requirements of IEEE P802.3an, Class E<sub>A</sub> requirements of amendment 1 to 2<sup>nd</sup> Edition ISO/IEC 11801, amendment 2 to 2<sup>nd</sup> Edition ISO/IEC 11801 (Draft 25 N 1645), and amendment 1 to CENELEC EN 50173-1:2007 (Draft EN 50173-1 prAA June 2008), and Category 6A requirements of ANSI/TIA/EIA-568-B.2-10. The permanent link is only specified for screen continuity and screening performance has therefore not been verified. The Attestation of Conformity is only valid for the actually tested permanent link samples in T568B configuration connected with RJ 45 plugs from Legrand patch cords, P/N 51780, P/N 51781, P/N 51782 and P/N 51783, and consisting of the following Legrand components:*

<i>Cable:</i>	<i>Horizontal Cable,</i>	<i>P/N 32777</i>
	<i>Qualification Status:</i>	<i>Manufacturer verified</i>
<i>Conn. Hardware:</i>	<i>Modular Jacks,</i>	<i>P/N SA63 and</i>
		<i>P/N SB63</i>
		<i>having PCB Marking C6A Link EP2904</i>
	<i>Qualification Status:</i>	<i>Manufacturer Verified</i>

Hoersholm, 9<sup>th</sup> June 2009

*Ole Lambertsen*

Ole Lambertsen  
Test Responsible

Hoersholm, 9<sup>th</sup> June 2009

*Paul Villien*

Poul Villien  
Coordinating Manager