



# Attestation of Conformity

## ISO/IEC, EN & TIA/EIA Screen Continuity Class E / Category 6 Three Connector Channel

**Legrand**  
**128 Avenue de Lattre de Tassigny**  
**F-87045 Limoges Cedex, France**

### *Attestation of Conformity No. 109614*

*This type of Class E / Category 6 screen continuity three connector channel has been tested by 3P Third Party Testing and complies with Class E channel requirements of 2<sup>nd</sup> Edition ISO/IEC 11801 and CENELEC EN 50173-1:2007, and Category 6 channel requirements of ANSI/TIA/EIA-568-B.2-1. The channel is only specified for screen continuity and screening performance has therefore not been verified. The Attestation of Conformity is only valid for the actually tested channel samples in T568B configuration, and consisting of the following Legrand components:*

<i>Cables:</i>	<i>Horizontal Cables,</i>	<i>P/N 32856 and P/N 32756, and from consolidation cords P/N 51796, P/N 51797 and P/N 51798</i>
	<i>Flexible Cable from cords,</i>	<i>P/N 51762, P/N 51763, P/N 51764 and P/N 51765</i>
	<i>Qualification Status:</i>	<i>Manufacturer verified</i>
<i>Conn. Hardware:</i>	<i>Modular Jacks,</i>	<i>P/N SA52 and P/N SB52</i>
		<i>having PCB Marking HS000 97AA C5E C6</i>
	<i>Qualification Status:</i>	<i>Manufacturer Verified</i>
<i>Consolidation Cords:</i>	<i>8,0 m, 15,0 m and 20,0 m,</i>	<i>P/N 51796, P/N 51797 and P/N 51798</i>
<i>Equipment Cords:</i>	<i>1,0 m, 2,0 m, 3,0 m and 5,0 m,</i>	<i>P/N 51762, P/N 51763, P/N 51764 and P/N 51765</i>
	<i>Qualification Status:</i>	<i>Manufacturer Verified</i>

Hoersholm, 6<sup>th</sup> July 2009

*Ole Lambertsen*

Ole Lambertsen  
Test Responsible

Hoersholm, 6<sup>th</sup> July 2009

*Paul Villien*

Poul Villien  
Coordinating Manager